



Mahatma Phule Renewable Energy and Infrastructure Technology Limited

(Subsidiary of MPBCDC, a Government of Maharashtra undertaking) CIN No. U40106MH2021SGC358784

Ref: RFQ No: MAHAPREIT/ETAP/RFQ – 11/2025

Date: 16/07/2025

1st Extension Notice & Reply to Pre-Bid Queries

Request for Qualification (RFQ)

For

“Empanelment of Agencies for Design, Installation, Commissioning and Operating of Active Magnetic Bearing Energy-Efficient Turbo Blowers for Sewage Treatment Plants (STPs) via ESCO Mechanism in Maharashtra and Other States.”

Tender no: - RFQ No: MAHAPREIT/ETAP/RFQ – 11/2025

With reference to Request for Qualification (RFQ) for “Empanelment of Agencies for Design, Installation, Commissioning and Operating of Active Magnetic Bearing Energy-Efficient Turbo Blowers for Sewage Treatment Plants (STPs) via ESCO Mechanism in Maharashtra and Other States.”, it is hereby conveyed that:

1. The last date of bid submission of above mentioned RFQ has been extended to 23/07/2025 at 15:00 Hrs.
2. Time and date of Opening of RFQ on 24/07/2025 at 16.00 Hrs.
3. Reply to Pre-Bid Queries: The responses to the pre-bid queries raised by prospective bidders are attached herewith.

The other Terms and Conditions shall be remaining unchanged.

Sd/-

**CGM (RESCO-II)
MAHAPREIT Ltd.**

Reference Website: 1. <https://mahatenders.gov.in>
4. <https://mahapreit.in>

Tender Name: - “Empanelment of Agencies for Design, Installation, Commissioning and Operating of Active Magnetic Bearing Energy-Efficient Turbo Blowers for Sewage Treatment Plants (STPs) via ESCO Mechanism in Maharashtra and Other States”.

Tender No: - MAHAPREIT/ETAP/RFQ – 11/2025

RFQ No: MAHAPREIT/ETAP/RFQ – 11/2025				
Sr. No.	Page No.	Clause No.	Queries by Bidders	Replies by MAHAPREIT
1. M/s. Virtual Galaxy InfoTech Ltd.				
1.1	13	3.10.1 The Original Equipment Manufacturer (OEM) must provide either a valid CE compliance certificate or ASME certification for the offered blower technology — submission of any one is mandatory.	Will the CE mark (self-declaration under EU Machinery Directive) be accepted as valid CE compliance, or is a Notified Body CE certificate specifically required?	Bidder shall submit either an ASME certification or a CE compliance certificate issued by the OEM for the blower technology. CE compliance shall be considered equivalent to ASME certification for the purpose of technical evaluation.
1.2	41	Annexure 13 The relevant ISO certifications (such as ISO 9001 for quality management or ISO 14001 for environmental management) may be submitted to support overall OEM credibility but are not a substitute for CE/ASME certification."	Is there flexibility to consider CE + ISO certifications as compliant if the OEM lacks ASME but meets other technical criteria?	The Original Equipment Manufacturer (OEM) must provide either a valid CE compliance certificate or ASME certification for the offered blower technology — submission of any one is mandatory. Additionally, relevant ISO certifications (such as ISO 9001 for quality management or ISO 14001 for environmental management) may be submitted to support overall OEM credibility but are not a substitute for CE/ASME certification.
2. M/s. Larasun Engineering				
2.1	13	3.10.1 The Original Equipment Manufacturer (OEM) must provide either a valid CE compliance certificate or ASME	CE compliance certificate to be accepted	Bidder shall submit either an ASME certification or a CE compliance certificate issued by the OEM for the blower technology. CE compliance shall be considered equivalent

Tender Name: - “Empanelment of Agencies for Design, Installation, Commissioning and Operating of Active Magnetic Bearing Energy-Efficient Turbo Blowers for Sewage Treatment Plants (STPs) via ESCO Mechanism in Maharashtra and Other States”.

Tender No: - MAHAPREIT/ETAP/RFQ – 11/2025

		certification for the offered blower technology — submission of any one is mandatory.		to ASME certification for the purpose of technical evaluation.
2.2	14	3.11.10 The Bidder will have to pay Energy Saving sharing to MAHAPREIT for which separate offer will be obtained from the successful empanelled Bidder on case to case basis.	Please explain the clause.	Tender Condition Prevailed.
2.3	29	Annexure 3 Power of Attorney Format	It required to be notarized on Rs. 500 stamp paper	<ul style="list-style-type: none"> • Yes. The Power of Attorney must be executed on a non-judicial stamp paper of appropriate value (as per the Indian Stamp Act applicable to the place of execution). • Notarization is mandatory to validate the authorization.
2.4	41	Certifications (for OEM)	CE / ASME any one Mandatory, Any ISO document can be submitted	Bidder shall submit either an ASME certification or a CE compliance certificate issued by the OEM for the blower technology. CE compliance shall be considered equivalent to ASME certification for the purpose of technical evaluation.
2.5	32	Annexure 6 Assignments of similar nature during last 3 years	For Similar nature to mean - submission of information of PO for supply and commissioning of	Bidders may submit either <ul style="list-style-type: none"> i. ESCO-based projects (preferred) demonstrating energy savings in STPs/CETPs, or

Tender Name: - “Empanelment of Agencies for Design, Installation, Commissioning and Operating of Active Magnetic Bearing Energy-Efficient Turbo Blowers for Sewage Treatment Plants (STPs) via ESCO Mechanism in Maharashtra and Other States”.

Tender No: - MAHAPREIT/ETAP/RFQ – 11/2025

			Magnetic Turbo Blowers and not ESCO assignments.	ii. Supply/commissioning contracts for Magnetic Turbo Blowers in wastewater treatment plants.
3. M/s. Usha Neuros Turbo LLP				
3.1	NA	NA	Request to consider Air Foil Bearing (AFB) Turbo Blowers as alternative to Active Magnetic Bearing (AMB) blowers.	Please Read Active Magnetic Bearing (AMB) Or Air Foil Bearing (AFB) technology in place of Active Magnetic Bearing (AMB), in all places of RFQ. Read both accepted.